

RESOLUTION No. 2008-150-837

A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF MIAMI GARDENS, FLORIDA, AUTHORIZING THE CITY MANAGER AND CITY CLERK TO EXECUTE AND ATTEST, RESPECTIVELY, THAT CERTAIN UNDERGROUND DISTRIBUTION FACILITIES INSTALLATION AGREEMENT WITH FP&L FOR THE INSTALLATION OF FACILITIES AT MIAMI GARDENS COMMUNITY CENTER, A COPY OF WHICH IS ATTACHED HERETO AS EXHIBIT A; PROVIDING FOR INSTRUCTIONS TO THE CITY CLERK; PROVIDING FOR THE ADOPTION OF REPRESENTATIONS; PROVIDING AN EFFECTIVE DATE.

WHEREAS, in order to provide electrical service to the Miami Gardens Community Center, Florida Power & Light requires an Agreement for the installation of underground facilities, and

WHEREAS, City Council would like to authorize the City Manager to execute an Agreement for this purpose,

NOW, THEREFORE, BE IT RESOLVED BY THE CITY COUNCIL OF THE CITY OF MIAMI GARDENS, FLORIDA, as follows:

Section 1. ADOPTION OF REPRESENTATIONS: The foregoing Whereas paragraphs are hereby ratified and confirmed as being true, and the same are hereby made a specific part of this Resolution.


Section 2. AUTHORITY: The City Manager and City Clerk are hereby authorized and directed to execute and attest, respectively, that certain Underground Distribution Facilities Installation Agreement with FP&L for the installation of facilities at Miami Gardens Community Center, a copy of which is attached hereto as **Exhibit A**.

Section 3. INSTRUCTIONS TO THE CITY CLERK: The City Clerk is hereby authorized to obtain three (3) fully executed copies of the subject Agreement, with one

to be maintained by the City; with one to be delivered to FP&L, and with one to be directed to the Office of City Attorney.

Section 4. EFFECTIVE DATE: This Resolution shall take effect immediately upon its final passage.

PASSED AND ADOPTED BY THE CITY COUNCIL OF THE CITY OF MIAMI GARDENS AT ITS REGULAR MEETING HELD ON JULY 23, 2008.


SHIRLEY GIBSON, MAYOR

ATTEST:


RONETTA TAYLOR, CMC, CITY CLERK

PREPARED BY: SONJA KNIGHTON DICKENS, ESQ.
City Attorney

SPONSORED BY: DANNY CREW, CITY MANAGER

MOVED BY: Vice Mayor Watson
SECOND BY: Councilman Gilbert

VOTE: 6-0

Mayor Shirley Gibson	<u> X </u> (Yes)	<u> </u> (No)
Vice Mayor Barbara Watson	<u> X </u> (Yes)	<u> </u> (No)
Councilman Melvin L. Bratton	<u> X </u> (Yes)	<u> </u> (No)
Councilman Aaron Campbell	<u> X </u> (Yes)	<u> </u> (No)
Councilman Oliver Gilbert, III	<u> X </u> (Yes)	<u> </u> (No)
Councilwoman Sharon Pritchett	<u> </u> (Yes)	<u> </u> (No) (not present)
Councilman André Williams	<u> X </u> (Yes)	<u> </u> (No)

SKD/teh
8141329_1.DOC



UNDERGROUND DISTRIBUTION FACILITIES INSTALLATION AGREEMENT

This Agreement, made this 13 day of June, 2008, by and between CITY OF MIAMI-GARDENS (hereinafter called the Customer) and FLORIDA POWER & LIGHT COMPANY, a corporation organized and existing under the laws of the State of Florida (hereinafter called FPL).

WITNESSETH:

Whereas, the Customer has applied to FPL for underground distribution facilities to be installed on Customer's property known as CAROL CITY COMMUNITY CENTER located in Miami-Gardens/Dade, Florida.
(City/County)

That for and in consideration of the covenants and agreements herein set forth, the parties hereto covenant and agree as follows:

1. The Customer shall pay FPL a Contribution in Aid of Construction of \$11,389.83 (the Contribution) to cover the differential cost between an underground and an overhead system. This is based on the currently effective tariff filed with the Florida Public Service Commission by FPL and is more particularly described on Exhibit A attached hereto.
2. That a credit of \$2,266.30 shall be provided to the Customer for trenching, backfilling, installation of Company provided conduit and other work, as shown on Exhibit A, if applicable, and approved by FPL.
3. The contribution and credit are subject to adjustment when FPL's tariff is revised by the Florida Public Service Commission and the Customer has requested FPL to delay FPL's scheduled date of installation. Any additional costs caused by a Customer's change in the Customer's plans submitted to FPL on which the contribution was based shall be paid for by the Customer. The contribution does not include the cost of conversion of any existing overhead lines to underground or the relocation of any existing overhead or underground facilities to serve the property identified above.
4. That the Contribution provides for 120/208 volt, three phase (120/208 volt, three-phase for URD Area) underground electrical service with facilities located on private property in easements as required by FPL. The contribution is based on employment of rapid production techniques and cooperation to eliminate conflicts with other utilities. Underground service, secondary, and primary conductors are to be of standard FPL design, in conduit, and with above-grade appurtenances.
5. That the payment of the Contribution does not waive any provisions of FPL's Electric Tariff.

If the property is subject to an underground ordinance, FPL shall notify the appropriate governmental agency that satisfactory arrangements have been made with the Customer as specified by FPL.

Title to and ownership of the facilities installed as a result of this agreement shall at all times remain the property of FPL.

6. That good and sufficient easements, including legal descriptions and survey work to produce such easements, and mortgage subordinations required by FPL for the installation and maintenance of its electric distribution facilities must be granted or obtained, and recorded, at no cost to FPL, prior to trenching, installation and/or construction of FPL facilities. FPL may require mortgage subordinations when the Customer's property, on which FPL will install its facilities, is mortgaged and (1) there are no provisions in the mortgage that the lien of the mortgage will be subordinate to utility easements, (2) FPL's easement has not been recorded prior to the recordation of the mortgage, (3) FPL's facilities are or will be used to serve other parcels of property, or (4) other circumstances exist which FPL determines would make such a subordination necessary.
 - a) The Customer shall furnish FPL a copy of the deed or other suitable document, which contains a full legal description, and exact name of the legal owner to be used when an easement is prepared, as required by FPL.
 - b) The Customer shall furnish drawings, satisfactory to FPL, showing the location of existing and proposed structures on the Customer's construction site, as required by FPL.
 - c) Should for any reason, except for the sole error of FPL, FPL's facilities not be constructed within the easement, FPL may require the customer to grant new easements and obtain any necessary mortgage subordinations to cover FPL's installed facilities, at no cost to FPL, and FPL will release the existing easement. Mortgage subordinations will be necessary in this context when 1) the Customer's property on which FPL will install its facilities is mortgaged, 2) there are no provisions in the mortgage for subordination of the lien of the mortgage to utility easements, or 3) FPL's facilities are or will be used to serve other parcels of property.

7. Before FPL can begin its engineering work on the underground electric distribution facilities, the Customer shall provide FPL with the following:
- a) Paving, grading, and drainage plans showing all surface and sub-surface drainage satisfactory to FPL,
 - b) A construction schedule,
 - c) An estimate of when electric service will be required, and
 - d) Copies of the Customer's final construction plans as well as other construction drawings (plot, site, sewage, electrical, etc.) requested by FPL. Plans provided by the Customer must be either recorded by the circuit clerk or other recording officer or prepared and certified as meeting the requirements for recording (except approval by the governing body) by a registered land surveyor.
8. Prior to FPL construction pursuant to this agreement, the Customer shall:
- a) Clear the FPL easement on the Customer's property of tree stumps, all trees, and other obstructions that conflict with construction, including the drainage of all flooded areas. The Customer shall be responsible for clearing, compacting, boulder and large rock removal, stump removal, paving and addressing other special conditions. The easement shall be graded to within six inches of final grade with soil stabilized.
 - b) Provide property line and corner stakes, designated by a licensed surveyor, to establish a reference for locating the underground cable trench route in the easement and additional reference points when required by FPL. Also, the Customer shall provide stakes identifying the location, depth, size and type facility of all non-FPL underground facilities within or near the easement where FPL distribution facilities will be installed. The Customer shall maintain these stakes, and if any of these stakes are lost, destroyed or moved and FPL requires their use, the Customer shall replace the stakes at no cost to FPL, unless the stakes are lost, destroyed or moved by an agent, employee, contractor or subcontractor of FPL, in which case FPL will pay the Customer the cost of replacing the stakes.
 - c) It is further understood and agreed that subsequent relocation or repair of the FPL system, once installed, will be paid by the Customer if said relocation or repair is a result of a change in the grading by the Customer or any of the Customer's contractors or subcontractors from the time the underground facilities were installed; and, that subsequent repair to FPL's system, once installed, will be paid by the Customer if said repair is a result of damage caused by the Customer or any of the Customer's contractors or subcontractors.
 - d) Provide sufficient and timely advance notice (30 days) as required by FPL, for FPL to install its underground distribution facilities prior to the installation of paving, landscaping, sodding, sprinkler systems, or other surface obstructions. In the absence of sufficient coordination, as determined by FPL, by the Customer, all additional costs for trenching and backfilling shall be paid by the Customer, and none of the costs of restoring paving, landscaping, grass, sprinkler systems and all other surface obstructions to their original condition, should they be installed prior to FPL's facilities, shall be borne by FPL.
 - e) Pay for all additional costs incurred by FPL which may include, but are not limited to, engineering design, administration and relocation expenses, due to changes made subsequent to this agreement on the subdivision or development layout or grade.
 - f) Provide applicable trenching, backfilling, installation of Company provided conduit and other work in accordance with FPL specifications more particularly described on Exhibit B attached hereto. At the discretion of FPL, either correct any discrepancies, within two (2) working days, found in the installation that are inconsistent with the instructions and specifications attached to this agreement or pay the associated cost to correct the installation within thirty (30) days of receiving the associated bill, and in either case, reimburse FPL for costs associated with lost crew time due to such discrepancies.
 - g) Provide a meter enclosure, downpipe and ell which meet all applicable codes and FPL specifications and which will accommodate FPL's service cable size and design. These items must be confirmed with FPL prior to purchase. FPL will not be responsible for costs involved in procuring or replacing items which do not meet the above criteria.
9. FPL shall:
- a) Provide the Customer with a plan showing the location of all FPL underground facilities, point of delivery, and transformer locations and specifications required by FPL and to be adhered to by the Customer.
 - b) Install, own, and maintain the electric distribution facilities up to the designated point of delivery except when otherwise noted.
 - c) Request the Customer to participate in a pre-construction conference with the Customer's contractors, the FPL representatives and other utilities within six (6) weeks of the start of construction. At the pre-construction conference, FPL shall provide the Customer with an estimate of the date when service may be provided.
10. This Agreement is subject to FPL's Electric Tariff, including but not limited to the General Rules and Regulations for Electric Service and the Rules of the Florida Public Service Commission, as they are now written, or as they may be revised, amended or supplemented.
11. This agreement shall inure to the benefit of, and be binding upon, the successors and assigns of the Customer and FPL.

The Customer and FPL will coordinate closely in fulfilling obligations in order to avoid delays in providing permanent electric service at the time of the Customer's receipt of a certificate of occupancy.

Accepted: John Harris 6/16/08
 FPL (Date)

Robert Smith Taylor
 City Clerk

Accepted: [Signature] 7/31/08
 Customer (Date)
Krista Woods 7/31/08
 Witness (Date)
M. Buttrick 7/31/08
 Witness (Date)



TRANSFORMER PAD LOCATION AND SPECIFICATION

PROJECT: Coral City Community Center
 ADDRESS: NW 199th ST & 31st AVE

DATE: June 13, 2008
 FPL WR # 3032280

CUSTOMER AGREES TO:

Provide recorded easement for all FPL facilities on Customer's property. FPL will not start construction until these easements are cleared by the customer of all conflicts preventing construction. Should paving, grass, landscaping or sprinkler systems be installed prior to construction of the underground distribution facilities, the customer will bear the cost of restoring same to their original condition.

Provide location and depth information for all underground facilities and fill or cut to within 6 inches of final grade within the easement. (See attached referenced prints.)

Notify FPL representative two weeks in advance of paving schedule so that FPL can install ducts if required.

Make arrangements for location of FPL pads as shown on location sketch. Provide and install secondary service to padmount transformer. Use a maximum of 8 cables per leg. (See pad detail for entrance space availability for customer service cable) Terminate conduits 3 inches above final grade and provide 7 feet of cable per leg beyond the conduit ends for connection to transformer terminals.

Compact and level 3 inches below final grade an area sufficient for the concrete pad. Provide clear space of 8 feet at the front and 4 feet at sides and rear of the transformer pad to allow for a safe working area.

~~Keep area above transformer pad clear to allow setting transformer with a crane. If current transformers are required, provide and install 1 1/4 inch rigid conduit from CT's to meter location. Maximum horizontal distance from pad to meter is 10 feet.~~

Provide a clear space 36 inches in front of meters. If built up meter centers are to be used, provide FPL representative with shop drawings of centers and layout sketch of meter room for FPL approval prior to purchase

FPL AGREES TO:

Provide primary ducts.

Provide and install padmount transformer.

Provide and install cables from FPL facilities to the padmounted transformer.

Provide and install ground rods at the transformer.


Connect customer's service cables to FPL facilities in transformer compartment.

Provide meter wiring when current transformers are required.

Provide 120/208 volt Three-Phase service.

REPRESENTING CUSTOMER:

I hereby certify that I am authorized to accept these specifications on behalf of the customer and that I have delivered a copy of these specifications to the customer and all affected contractors.

NAME: 
(signature)

DATE: 7/31/08

NAME: DR. DANNY O. CREW
(print or type)

TITLE: CITY MANAGER


TELEPHONE # (305) 622-8007

Approved as to form and legal sufficiency


Sonja K. Dickens, City Attorney

REPRESENTING FPL:

I hereby certify that I am authorized to accept these specifications on behalf of Florida Power and Light Company.

NAME: 

DATE: 6/14/08

City of Miami Gardens

1515-200 NW 167th Street
Miami Gardens, Florida 33169



Mayor Shirley Gibson
Vice Mayor Barbara Watson
Councilman Melvin L. Bratton
Councilman Aaron Campbell Jr.
Councilman Oliver G. Gilbert, III
Councilwoman Sharon Pritchett
Councilman André Williams

Agenda Cover Page

Date: **July 23, 2008**

Fiscal Impact: No Yes

(If yes, explain in Staff Summary)

Funding Source: SNP- CCCC

Contract/P.O. Requirement: Yes No

Sponsor Name/Department:

Antranette Pierre, Capital Projects

Public hearing

Ordinance

1st Reading

Advertising requirement: Yes No

RFP/RFQ/Bid #

Quasi-Judicial

Resolution

2nd Reading

Title

A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF MIAMI GARDENS, FLORIDA, AUTHORIZING THE CITY MANAGER AND CITY CLERK TO EXECUTE AND ATTEST, RESPECTIVELY, THAT CERTAIN UNDERGROUND DISTRIBUTION FACILITIES INSTALLATION AGREEMENT WITH FP&L FOR THE INSTALLATION OF FACILITIES AT MIAMI GARDENS COMMUNITY CENTER, A COPY OF WHICH IS ATTACHED HERETO AS EXHIBIT A; PROVIDING FOR INSTRUCTIONS TO THE CITY CLERK; PROVIDING FOR THE ADOPTION OF REPRESENTATIONS; PROVIDING AN EFFECTIVE DATE.

Staff Summary

As part of installing electrical service for the Miami Gardens Community Center, Florida Power & Light require an agreement for the underground distribution of facilities. This agreement addresses the responsibilities of FP&L including installation of cables, transformer, and ground rods, as well as the provision of a service meter. The City's responsibilities include the coordination of the community center construction with the underground utility connections.

RECOMMENDATION:

It is recommended that the City Council approve the agreement authorizing the City Manager to execute the agreement between Florida Power & Light and the City of Miami Gardens for electrical service at the Miami Gardens Community Center.